

**KEMA TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS**

**Object** Low-voltage switchgear and controlgear assembly **5056-16**

**Type** Form 4 2501 A **Serial No.** 264-432.01

Rated voltage 400 V Rated current 2501 A  
 Rated short-circuit current 65 kA Rated frequency 50 Hz

**Manufacturer** Cenika AS,  
 Industrigata 13, 3414 Lierstranda, Norway \*)

**Client** Finelcomp OY,  
 Yrittäjänkatu 6, FI-83501 Outokumpu, Finland

**Tested by** KEMA Laboratories Prague,  
 Zkušebnictví, a.s., Podnikatelská 547, Prague 9, the Czech Republic

**Date of tests** 09 February to 28 April 2016

The object, constructed in accordance with the description, drawings and photographs incorporated in this Certificate has been subjected to the series of proving tests in accordance with

**IEC 61439-2:2011, IEC 61439-1:2011**

The results are shown in the record of proving tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above standard(s) and to justify the ratings assigned by the manufacturer as listed on page 10.

This Certificate applies only to the object tested. The responsibility for conformity of any object having the same type references as that tested rests with the Manufacturer.

\*) as declared by the manufacturer

This Certificate consists of 415 pages in total.

Zkušebnictví, a. s.



Robert Jech  
 Operational Manager



Prague, 27 March 2017